



Certificate of Compliance

Certificate: 2711121

Master Contract: 240515

Project: 2711121

Date Issued: March 26, 2014

Issued to: Telemecanique/Schneider Electric

Industries SAS
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France
Attention: Mr. Christophe Delaître

The products listed below are eligible to bear the CSA Mark shown



J.-C. Chow

Issued by: J.-C. Chow

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Trip-wire-operated emergency-stop switches, Model XY2CJ, contact-rating: A300 and Q300, for two-contacts (1NC+1NO, or 2NC) model; B300 and R300, for three-contacts (2NC+1NO, or 1NC+2NO) model; enclosure Type 4 or 12.

Note: Enclosure Type 4 or 12 only when provided with 1/2-inch NPT threaded entries, or with metric-NPT adaptors for trade size conduits.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-13 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures



Supplement to Certificate of Compliance

Certificate: 2711121

Master Contract: 240515

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2711121	Mar 26, 2014	Initial CSA Certification Trip-wire-operated emergency-stop switches, Model XY2CJ, contact-rating A300/Q300 for two-contacts model, B300/R300 for three-contacts model, enclosure Type 4 or 12.